



OFFICE OF THE DEPUTY FIRE OFFICER
ROURKELA CIRCLE, ROURKELA
Email ID-dforkl-ofs@gov.in

No-FSC/94/2020/ 115 /RKL CIRCLE
To

Dtd. 17.01.2021.


The Principal
Green Field School
At- Khudatanga
At/P.O-Polaspanga
Dist-Keonjhar

Sub- Fire safety inspection report in favour of Green Field School, At/P.O-Palaspanga, Dist-Keonjhar.

Sir,

With reference to the subject cited above this is to intimate that as per plan school is functioning in 5no buildings. All the buildings are of single storied. Built up area of block-1 is 246.4sqm, block-2- 553sqm, block-3-301.3sqm, block-4-257.8sqm and block-5 office building is of 233.5sqm. All the buildings are separate from each other and adequate open space is available. The height of each building is less than 9mtrs. The school building has adequate exit ways from class rooms. The school buildings are abutting to 12m width road. As per Rule-9 (J) of Odisha Fire Prevention and Fire Safety (Amendment) Rules-2019 your school is not coming for consideration of issuance of fire safety certificate. The school management has provided good number of fire extinguishers in the school buildings which comply the minimum requirement.

Yours Faithfully,


Deputy Fire Officer
Rourkela Circle, Rourkela
Deputy Fire Officer
Rourkela Circle, Rourkela